



Note 1: Tie-in detail for all flat surfaces. The use of Detail 1070/T1070 will be required in conjunction with this detail when tie-in is across metal flutes.

Note 2: All field welds shall be a minimum of 1-1/2 in. (40 mm) wide.

Note 3: Refer to specifications for vapor barrier, insulation and cover board requirements.

|           |            |  |
|-----------|------------|--|
| REVISED:  | N/A        | GENERAL DETAIL FOR MECHANICALLY FASTENED SYSTEMS |
| PREVIOUS: | 01/19/2026 | PVC/TPO TIE-IN STRIP                             |
| SCALE:    | NONE       | RE-ROOF  |